


**APPENDIX 4 TYPE VERIFICATION TEST SHEET****SSEG DETAILS**

SSEG Type reference:		<i>Fronius IG TL 3.6</i>
SSEG Technology:		<i>Photo voltaic (Annex C)</i>
Manufacturer: <i>Fronius International GmbH</i>	Tel: <i>+43-7242-241-0</i>	Address: <i>Guenter Fronius Str 1 4600 Wels-Thalheim, Austria</i>
	Fax: <i>+43-7242-241-224</i>	
Technical file reference No.:		
Maximum export capability (SSEG rating less parasitic load)		3680W

TEST HOUSE DETAILS

Name and address of test house	<i>Fronius R&D Laboratories, Fronius International GmbH, Guenter Fronius Str 1, A-4600 Wels-Thalheim, Austria</i>
Telephone number	<i>+43-7242-241-0</i>
Facsimile number	<i>+43-7242-241-224</i>
E-mail address	<i>pv@fronius.com</i>

Test details

Date of test	Tuesday, 15 December 2009
Name of test Engineer	Riedler Peter
Signature of test Engineer	
Test location if different from above	



POWER QUALITY

Harmonic current emissions (A) Maximum permissible harmonic current as per BS EN 61000-3-2								
Harmonic	2 nd	3 rd	5 th	7 th	9 th	11 th	13 th	15 th – 39 th
Limit	1,08	2,3	1,14	0,77	0,4	0,33	0,21	0,15x(15/n)
Test value (max value of Phase1,2,3)	0,166	0,263	0,119	0,056	0,106	0,048	0,097	See TR LF_09042

Harmonic current emissions (A) Maximum permissible harmonic current as per BS EN 61000-3-12								
Harmonic	2 nd	3 rd	5 th	7 th	9 th	11 th	13 th	15 th – 39 th
Limit	1,73	8,86	5,19	3,24	2,59	2,16	1,73	0,15x(15/n)
Test value (max value of Phase1,2,3)	0,2	0,424	0,178	0,103	0,147	0,081	0,128	See TR LF_09042

Voltage Fluctuations and Flicker				
	Starting	Stopping	Running	
Limit*	4%	4%	P _{st} = 1.0	P _{lt} = 0.65
Test value	NA **	NA**	NA**	NA**

*Maximum permissible voltage fluctuation (expressed as a percentage of nominal voltage at 100% power) and flicker. As per BS EN 61000-3-11.

** The EUT itself does not produce flicker relevant variations of the line current, startup is made using a ramp function and does therefore not create relevant d_{MAX} values.

Solar power variations naturally lead to variations of the electric power fed into the grid, however these variations are not significant for P_{ST} and P_{LT}.

	DC injection*			Power factor		
G83/1 Limit	20mA, tested at three power levels			0.95 lag–0,95 lead at three voltage levels		
Test level	10%	55%	100%	212 V	230 V	248 V
Test value	±20mA	±20mA	±20mA	0,99	0,99	0,99

**UNDER / OVER FREQUENCY TESTS**

Parameter	Under Frequency		Over Frequency	
	Frequency (Hz)	Time (s)	Frequency (Hz)	Time (s)
G83/1 Limit	47 Hz	0,5 sec	50,5 Hz	0,5 sec
Actual setting	47,02 Hz	0,4 sec	50,48 Hz	0,4 sec
Trip value	>47Hz	<0,5 sec	<50,5 Hz	<0,5 sec

UNDER / OVER VOLTAGE TESTS

SSEG is configured to comply with the lower over voltage trip value.

Parameter	Under Voltage		Over Voltage	
	Voltage (V)	Time (s)	Voltage (V)	Time (s)
G83/1 Limit	207 V	1,5 sec (*)	264 V (*)	1,5 sec (*)
Actual setting	209,07 V	1,2 sec	261,36 V	1,2 sec
Trip value	>207V	<1,5 sec	<264 V	<1,5 sec

*The Fronius IG TL is configured by default in accordance with the "Engineering Recommendation G83/1". The "Engineering Recommendation G59/1" applies if the following changes would be done. Please contact your Fronius Customer Service for further information.

- U inner Limit max From 264V (G83/1) to 253V (G59/1)
- U inner Limit max Trip From 1,5s (G83/1) to 0,5s (G59/1)
- U inner Limit min Trip From 1,5s (G83/1) to 0,5s (G59/1)

LOSS OF MAINS TEST

Method used	Frequency shift		
Output power level*	10%	55%	100%
Trip setting	0,5 sec	0,5 sec	0,5 sec
Trip value	<0,5 sec	<0,5 sec	<0,5 sec

*indicative values are shown for minimum, medium and maximum power levels.



RECONNECTION TIMES

Parameter	Under/Over voltage	Under/Over Frequency	Loss of mains
Minimum value	180 seconds	180 seconds	180 seconds
Actual setting	<i>185 seconds</i>	<i>185 seconds</i>	<i>185 seconds</i>
Recorded value	<i>>180 seconds</i>	<i>>180 seconds</i>	<i>>180 seconds</i>

SHORT CIRCUIT CURRENT CONTRIBUTION

As Photovoltaic SSEGs are inverter connected, they are deemed to automatically comply with clause 5.8 and no further tests are required.

COMMENTS

--